

21.8 System not running- “Tank empty” message

The message “Tank empty” appears on the display but the system does not go into Production.

- There may be another fault message, which you can read by scrolling with the arrow keys.
- Try adding approx. 5 cm of water to the tank
- The level sensor could be defective
- Check values for Aquasherriff with Siemens OBA6 control unit

Block 63

Actual values **On 15 – Off 7** change to **On 0 – Off -10**