

## 24. Disinfecting with henndrixx

Instructions for disinfecting the EASYRO system with the henndrixx disinfectant.

### Pre-filter:

- Remove the pre-filter
- Clean the housing with henndrixx
- Then fill with hendrixx and screw on again
- Start the system briefly so that henndrixx is sucked into the hoses up to the system
- Leave to work for at least 10 minutes
- Repeat the process in the case of heavy contamination

### EASYRO:

- Suck henndrixx into the system --- quantities the same as for maintenance
- Open blending valve during suction
- Leave to work for at least 10 minutes
- Repeat the process in the case of heavy contamination

### Tank:

#### Dosage:

Precautionary treatment	per 1000 litres of water	1 litre of henndrixx
Low bacterial contamination	per 1000 litres of water	1.5 litres of henndrixx
Slight contamination	per 1000 litres of water	2.5 litres of henndrixx
Heavy contamination	per 1000 litres of water	5 litres of henndrixx

- Add henndrixx to the tank
- Spray the upper area of the tank with henndrixx using a spray bottle
- Stir the tank so that henndrixx is well distributed in the water
- Leave to work for 10 minutes
- Pump the tank empty so that the high-pressure pump and the hose lines are also disinfected.
- Run the system briefly so that henndrixx is sucked out of the pre-filters.
- Insert new pre-filter and flush into the drain for at least 3 minutes!
- Start up the system and fill the tank.

The system should now be disinfected.

As a precaution, henndrixx can be added to the tank on a weekly basis.