

8. Change of outlet pressure EASYRO 60/120/240/480

Start from the start screen.

Press the down arrow.

The date and time appear

- Press ESC.
- Select Program and press OK.
- Select Set Parameter and press OK.
- Select B59 and press OK.
- ON and OFF are the 2 values for switching off the system. Press OK for the first value and you can adjust it (+00400 is 4 bar). Then confirm with OK. Do exactly the same on the 2nd line for OFF. The same value should then be set for ON and OFF.
- Scroll back with ESC until you are back in the blocks.
- Now select Block 69 and confirm with OK.
- Set the OFF value to the switch-on value – this must have a difference of 1 bar from the switch-off value.
- Then press ESC again until the display shows the date and time.
- Then press the up arrow and you are back on the start screen